

**BID MEMO**

**date:** 10 October 2018  
**to:** Plan Holders  
**owner:** CITY OF PAGE  
**architect:** WEDDLE GILMORE black rock studio  
**project:** Horseshoe Bend – Phase 2 Improvements

The following items modify or interpret the Bidding Documents dated September 4, 2018 by additions, deletions, clarifications or corrections. Where portions of the Bidding Documents are modified by this Bid Memo, the unaltered portions of the Bidding Documents shall remain in effect.

**Bid document additions, deletions, clarifications and corrections:**

**Item No. 01:** CIVIL CLARIFICATIONS

1. Questions 1: What type of Asphalt Mix is required in the City of Page structural sections? I found the mix requirement for the portion of project that is in ADOT ROW, it is Mix 409 (Miscellaneous Structural)  
**[RESPONSE]** Use MAG spec 321 for A/C, 702 for A/B.
2. Question 2: Sheet C2.0, detail 2 does not have callouts as to where it is to be applied, can you clarify please?  
**[RESPONSE]** See keynote 13, on sheet C2.3 for thickened edge.

**attachments:** none

**END OF BID MEMO**

cc: Kyle Christansen, City of Page  
Project File



Expires 12/31/2018

6916 east fifth avenue  
scottsdale arizona 85251

480 517 5055 studio  
480 517 5057 facsimile

weddlegilmore.com

WEDDLE  
GILMORE  
black  
rock  
studio