

ADDENDUM NO. 3

CITY OF PAGE
PAGE MUNICIPAL AIRPORT
RUNWAY 15-33 SAFETY AREA GRADING PROJECT, PHASE 1

In accordance with the Special Provisions to the General Provisions, SP 20-16, Addenda and Interpretation, the following revisions to the Plans and Specifications shall become a part of the Contract Documents and each bidder shall acknowledge receipt thereof on page PROPOSAL-18 of the Proposal Forms.

SPECIFICATIONS

ITEM 1: Replace pages Proposal-2 through Proposal-4 with **Attachment 'A'**.

QUESTIONS FROM BIDDERS:

ITEM 2: **Attachment 'B'** contains the bidders' questions received to date, with responses.



ATTACHMENT 'A'
PAGE MUNICIPAL AIRPORT
PAGE, ARIZONA
RUNWAY 15-33 SAFETY AREA GRADING PROJECT

ITEM NO.	FAA SPEC NO.	QUANTITY	ITEM LIST ITEM DESCRIPTION (PRICE WRITTEN IN WORD)	UNIT PRICE IN FIGURES		TOTAL AMOUNT	
				DOLLARS	CENTS	DOLLARS	CENTS
1	C-102	1 LS	COMPLIANCE WITH POLLUTION, ERIOSION, AND SILTATION CONTROL AT				
2	C-105	1 LS	MOBILIZATION AT				
3	C-106	1 LS	SAFETY, SECURITY AND MAINTENANCE OF TRAFFIC AT				
4	P-151	15 AC	CLEARING AND GRUBBING AT				
5	P-152	38000 CY	UNCLASSIFIED EXCAVATION AT				
6	D-701	2 EA	REMOVAL OF STORM DRAIN MANHOLE AT				
7	D-701	30 LF	REMOVAL OF STORM DRAIN PIPE - 48 INCH AT				
8	D-701	6 LF	REMOVE EXISTING PIPE AND BACKFILL TO MATCH BOTTOM OF EXISTING FENCELINE AT				
9	D-701	8 EA	CAP EXISTING PIPE AT				
10	D-701	2 EA	REMOVE EXISTING CONCRETE HEADWALL AT				
11	D-701	1 EA	REMOVE EXISTING CONCRETE SPILLWAY AT				

ATTACHMENT 'A'
PAGE MUNICIPAL AIRPORT
PAGE, ARIZONA
RUNWAY 15-33 SAFETY AREA GRADING PROJECT

ITEM NO.	FAA SPEC NO.	QUANTITY	ITEM LIST ITEM DESCRIPTION (PRICE WRITTEN IN WORD)	UNIT PRICE IN FIGURES		TOTAL AMOUNT	
				DOLLARS	CENTS	DOLLARS	CENTS
12	D-701	550 LF	INSTALL 36-INCH HDPE PIPE AT				
13	D-701	1250 LF	INSTALL 48-INCH HDPE PIPE AT				
14	D-751	3 EA	INSTALL STORM DRAIN MANHOLE AT				
15	D-751	1 EA	INSTALL CATCH BASIN TYPE_1 DOUBLE AT				
16	D-751	1 LS	REPAIR EXISTING CATCH BASIN AND SIDEWALK AT				
18	D-751	1 EA	INSTALL 48" HDPE FLARED END SECTION AT				
19	F-162	775 LF	REMOVE EXISTING CHAIN-LINK FENCE AT				
20	F-162	1125 LF	INSTALL NEW CHAIN-LINK FENCE AT				
21	L-100	18 EA	REMOVE AND SALVAGE EXISTING RUNWAY THRESHOLD OR EDGE LIGHT AND ISOLATION TRANSFORMER, BASE CAN TO REMAIN AT				
22	L-100	18 EA	INSTALL TEMPORARY STEEL COVER ON EXISTING L-867 BASE CAN AT				
23	L-100	10 EA	INSTALL TEMPORARY 4" PVC COVERS OVER EXISTING RUNWAY EDGE LIGHTS AT				

ATTACHMENT 'A'
PAGE MUNICIPAL AIRPORT
PAGE, ARIZONA
RUNWAY 15-33 SAFETY AREA GRADING PROJECT

ITEM NO.	FAA SPEC NO.	QUANTITY	ITEM LIST ITEM DESCRIPTION (PRICE WRITTEN IN WORD)	UNIT PRICE IN FIGURES		TOTAL AMOUNT	
				DOLLARS	CENTS	DOLLARS	CENTS
24	L-100	2 EA	INSTALL TEMPORARY THRESHOLD LIGHT BARS - 8 TEMPORARILY RELOCATED EXISTING RUNWAY THRESHOLD FIXTURES & ISOLATION TRANSFORMERS AT				
25	L-125	2 EA	REINSTALL EXISTING ELEVATED RUNWAY EDGE LIGHT AND ISOLATION TRANSFORMER ON EXISTING L-867 BASE CAN WITH NEW BOLTS AND GASKET AT				
26	L-125	18 EA	REINSTALL EXISTING ELEVATED RUNWAY END / THRESHOLD LIGHT (BI-DIRECTIONAL R/G) AND ISOLATION TRANSFORMER ON EXISTING L-867 BASE CAN WITH NEW BOLTS AND GASKET AT				
27	P-620	105355 SF	OBLITERATE PAVEMENT MARKINGS AT				
28	P-620	9500 SF	PAVEMENT MARKING (TEMPORARY, WHITE REFLECTORIZED) AT				
29	P-620	28000 SF	PAVEMENT MARKING (WHITE REFLECTORIZED) AT				
TOTAL PRICE (WRITTEN IN WORD)						DOLLARS	CENTS

ATTACHMENT 'B'

PAGE MUNICIPAL AIRPORT

RUNWAY 15-33 SAFETY AREA GRADING PROJECT, PHASE 1

ADDENDUM 3

Questions (Q) with Responses (A)

- Q. Will any airport safety training or badge training be required for either one of these projects listed above?
If so will it be in person or remote and roughly how many hours of training?
- A. No airport safety, badge or driver training will be required on this project.
- Q. There are two removal items on Sheet CD-102; Remove Existing Concrete Headwall and Remove Existing Concrete Spillway. However, there are no corresponding bid items for this work.
- A. These items have been added to the proposal forms included in this addendum.